

Monthly Simulation Results for Central Quente

TFM SISTEMAS DE AQUECIMENTO
ISEL

09-22-2013
07:43

Plant Simulation Results (Table 1) :

Month	Heating Coil Load (kWh)	Plant Load (kWh)	Boiler Output (kWh)	Boiler Input (kWh)	Boiler Misc. Electric (kWh)	Primary Hot Water Pump (kWh)
January	29933	29933	29933	34406	0	0
February	23868	23868	23868	27434	0	0
March	24915	24915	24915	28638	0	0
April	14295	14295	14295	16431	0	0
May	13243	13243	13243	15222	0	0
June	6255	6255	6255	7190	0	0
July	3544	3544	3544	4074	0	0
August	2807	2807	2807	3227	0	0
September	4206	4206	4206	4834	0	0
October	12815	12815	12815	14730	0	0
November	21896	21896	21896	25168	0	0
December	27259	27259	27259	31332	0	0
Total	185035	185035	185035	212684	0	0